

1 Connect Equipment



Battery Backup



Surge Protection


These outlets are powered whenever the Back-UPS is switched ON. During a power outage, or other utility problems (brownouts, over-voltages), these outlets will be powered for a limited time by the Back-UPS. Plug the computer and monitor into these two outlets.

Connect AC Power Cord


Plug the Back-UPS power cord into a wall outlet, not a surge protector or power strip. The outlet should be near the equipment and easily accessible.

Place the Back-UPS to avoid:


- Direct sunlight
- Excessive heat
- Excessive humidity or contact with fluids



ON/OFF and
LED Status
Indicator



Battery backup and
surge protected outlets



2 Turn on the Unit

Press ON/OFF to turn on the unit.

A single short beep, and the green “Power On” indicator confirms that the Back-UPS is on and ready to provide protection.

The Back-UPS should charge for at least 10 hours to ensure sufficient runtime. The unit is being charged whenever it is connected to utility power, whether the unit is turned ON or OFF.

Status Indicators

The Back-UPS ES indicates its operating status using a combination of visual and audible indicators. Use the following table to identify the status of the Back-UPS ES.

Power On LED	Buzzer	Condition
On	Off	On-line - Back-UPS is supplying conditioned utility power to the connected equipment
On (Off during 4 beeps)	4 beeps repeated every 30 seconds	On-Battery - Back-UPS is supplying battery power
Flashing	Rapid Beeping (every 1/2 second)	Low Battery Warning - The Back-UPS has 1.5 minutes of remaining battery power
Flashing	Constant tone	Bad Battery Detected - Battery needs to be charged, or is at end of life. (See <i>Battery Replacement</i> .)
Off	Short beep every 4 seconds	Low Battery Shutdown - During On Battery operation the battery power was almost completely exhausted, and the Back-UPS is waiting for utility power to return to normal
Off	Constant Tone	On Battery Overload - Connected equipment requires more power than provided by the Back-UPS battery. Unplug devices one at a time to remove overload, if not corrected Contact APC Technical Support
On	Constant Tone	On Line Overload - The power drawn by the connected equipment exceeds the power capacity of the Battery Backup
Flashing	Chirp every 2 seconds	Charger Warning -Back-UPS has experienced an internal problem, but continues to power the load. Contact APC Technical Support
Off	Constant Tone	Charger Fault - Back-UPS has an internal problem, and is no longer powering the load. Contact APC Technical Support

Transfer Voltage and Sensitivity Settings

LED Flashing	Transfer Voltage Setting	Input Voltage Range (For Utility Operation)	Usage
Once per second	Low (generator mode)	155 - 280	The Back-UPS will switch to battery power less often. Use with equipment that is not sensitive to low or high voltage levels or minor voltage waveform distortions. Use this setting when powering the Back-UPS with a generator.
Twice per second	Medium (factory default)	160 -280	Default, use in normal conditions.
Three times per second	High	165 - 270	The Back-UPS will switch to battery power during any small fluctuation in voltage. Use with equipment that is sensitive to low or high voltage levels or minor voltage waveform distortions.

Troubleshooting

Problem	Probable Cause	Solution
Back-UPS will not turn on.	Circuit Breaker has tripped.	Reduce the amount of equipment plugged into the “Battery Backup + Surge Protection” outlets. Reset the circuit breaker by pushing it back in.
	Utility power is not available at the wall outlet.	Ensure the fuse or circuit breaker for the wall outlet is okay, and the wall switch controlling the wall outlet (if any) is in the ON position.
Connected equipment loses power.	The Back-UPS is overloaded.	Ensure the equipment plugged into the outlets of the unit are not overloading the capacity of the unit. Try disconnecting some of the equipment one device at a time, and see if the problem continues.
	The Back-UPS has exhausted its available battery power.	The unit can only operate on battery power for a limited amount of time. The unit will eventually turn off when the available battery power has been used. Allow the unit to recharge for 10 hours before continuing to use the unit.
	The equipment connected to the Back-UPS does not accept the step-approximated sine waveform from the unit.	The output waveform is designed for computers and computer-related equipment. It is not designed for use with motor-type equipment.
The ON/OFF button is lit, and the unit is beeping four times every 30 seconds, or it is emitting a constant tone.	The Back-UPS may require service.	Contact APC Technical Support for further troubleshooting.
	The unit is using battery.	The unit is operating normally and using battery power. Save any current work, turn off all equipment, and turn the unit OFF. Once normal power is restored, turn the unit back ON, and turn on all equipment.
The On/Off button flashes once per second, and the Back-UPS beeps once per second at the same time.	Battery capacity is low (there is about 2 minutes of use remaining).	The unit is about to shut down due to a low battery charge condition! When the unit beeps once every second, the battery has about 2 minutes of power remaining. Immediately power down your computer, and turn the unit OFF. When power returns to normal, the unit will recharge the battery.
Inadequate runtime.	The battery is not fully charged.	Allow the unit to charge by leaving it plugged in, and switched on for 10 hours.
	The battery is near the end of useful life.	As a battery ages, the amount of runtime available will decrease. Batteries also age prematurely if the unit is placed near excessive heat. If the battery will not charge, the Back-UPS is no longer operable.

Specifications

Input	Voltage	230 VAC nominal
	Frequency	45-65 Hz
	Brownout Transfer	160 ±8% VAC, typical
	Over-voltage Transfer	280 VAC, typical
Output	UPS Capacity (total)	550 VA / 300 W
	Voltage On Battery	230 Vac rms (step-approximated sine wave)
	Frequency - On Battery	50 Hz±1Hz , 60Hz±1Hz
	Transfer Time	50 Hz: 6ms typical, 10ms maximum 60 Hz: 5ms typical, 8ms maximum
Protection and Filter	AC Surge Protection	Full time, 273 joules
	AC Input	Resettable circuit breaker
Battery	Type	7.5 Ah (maintenance free)
	Average Life	2 - 5 years depending on the number of discharge cycles and environmental temperature
	Typical Recharge Time	8-10 Hours
	Output Voltage Regulation (on battery)	230V ±8%
Physical	Net Weight	5.7 kg
	Dimensions (H x W x D)	18.5 cm (H) x 11.5 cm (W) x 21.3 cm (D)
	Operating Temperature	0 °C to 40 °C (32 °F to 104 °F)
	Storage Temperature	-15 °C to 45 °C (5 °F to 113 °F)
	Operating Relative Humidity	0 to 95% non-condensing
	Operating Elevation	0 to 3000 m (0 to 10,000 ft)
	2 power outlets	Both with battery backup and surge protection
	Adjustable Sensitivity and Transfer Voltage:	Low, Medium, and High
	Power Chord	1.2 Meters

Service

Please DO NOT RETURN Back-UPS to the place of purchase under any circumstances.

1. Consult the Troubleshooting section to eliminate common problems.
2. If you still have problems or questions, please contact APC via the internet or at one of the phone numbers listed below.
3. Before contacting APC, please be sure to record the date purchased, UPS model, and serial number (on bottom of unit).
4. Be prepared to troubleshoot the problem over the telephone with a Technical Support Representative. If this is not successful, the representative will issue a Return Material Authorization Number (RMA#) and a shipping address.
5. Pack the unit in its original packaging. If the original packaging is not available, ask APC Technical Support about obtaining a new set. Pack the unit properly to avoid damage in transit. Never use foam beads for packaging. Damage sustained in transit is not covered under warranty (insuring the package for full value is recommended).
6. Write the RMA# on the outside of the package.
7. Return the unit by insured carrier to the address given to you by APC Technical Support.

Limited Warranty

Two (2) years on electronics and battery from the date of manufacture against workmanship and manufacturing defects. APC’s standard procedure for any defect during the warranty period is to replace the faulty unit with a factory reconditioned unit. The customer is responsible for paying shipping charges both to and from the APC service center. However, APC reserves the right to repair the unit at the customer site or a location other than an APC service center. When applicable, the decision to recondition or replace a battery with a new or reconditioned battery lies solely with APC. The warranty shall be NULL and VOID if any unauthorized repair or modifications are carried out on the Back-UPS unit.

Exclusions: The following are not covered under the warranty:

1. Typical wear and tear.
2. Normal reductions in back up time or performance due to frequent discharge cycles, deep battery discharges, chronic power outages, insufficient recharging times, and operating in environmental conditions other than those recommended in the user manual.
3. Damage to the unit due to: abuse; negligence; high input voltages due to improper installation (example: lifted neutral, etc.); faulty building wiring; overloading; accidents at installation site; floods and acts of God.

Battery Replacement

The battery in the Back-UPS 550 is not user-replaceable. Contact APC Sales and Technical Support for a list of authorized service centers near you.

APC Contact Information

Customer Service:
Toll free (BSNL Network): 1-800-4254-272
All other networks: (add city code) 39022272

indiainfo@apc.com

www.apc.com/in